

Pt. 63, Subpt. ZZZZ, Table 3

40 CFR Ch. I (7–1–10 Edition)

[75 FR 9681, Mar. 3, 2010]

TABLE 3 TO SUBPART ZZZZ OF PART 63—SUBSEQUENT PERFORMANCE TESTS

As stated in §§63.6615 and 63.6620, you must comply with the following subsequent performance test requirements:

For each . . .	Complying with the requirement to . . .	You must . . .
1. 2SLB and 4SLB stationary RICE with a brake horsepower >500 located at major sources and new or reconstructed CI stationary RICE with a brake horsepower >500 located at major sources.	Reduce CO emissions and not using a CEMS.	Conduct subsequent performance tests semiannually. ¹
2. 4SRB stationary RICE with a brake horsepower ≥5,000 located at major sources.	Reduce formaldehyde emissions	Conduct subsequent performance tests semiannually. ¹
3. Stationary RICE with a brake horsepower >500 located at major sources.	Limit the concentration of formaldehyde in the stationary RICE exhaust.	Conduct subsequent performance tests semiannually. ¹
4. Existing non-emergency, non-black start CI stationary RICE with a brake horsepower >500 that are not limited use stationary RICE.	Limit or reduce CO or formaldehyde emissions.	Conduct subsequent performance tests every 8,760 hrs or 3 years, whichever comes first.
5. Existing non-emergency, non-black start CI stationary RICE with a brake horsepower >500 that are limited use stationary RICE.	Conduct subsequent performance tests every 8,760 hrs or 5 years, whichever comes first.

¹ After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semi-annual performance tests.

[75 FR 9682, Mar. 3, 2010]

TABLE 4 TO SUBPART ZZZZ OF PART 63—REQUIREMENTS FOR PERFORMANCE TESTS

As stated in §§63.6610, 63.6611, 63.6612, 63.6620, and 63.6640, you must comply with the following requirements for performance tests for stationary RICE for existing sources:

For each . . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
1. 2SLB, 4SLB, and CI stationary RICE.	a. Reduce CO emissions.	i. Measure the O ₂ at the inlet and outlet of the control device; and ii. Measure the CO at the inlet and the outlet of the control device.	(1) Portable CO and O ₂ analyzer.. (1) Portable CO and O ₂ analyzer..	(a) Using ASTM D6522–00 (2005) ^a (incorporated by reference, <i>see</i> §63.14). Measurements to determine O ₂ must be made at the same time as the measurements for CO concentration. (a) Using ASTM D6522–00 (2005) ^{a,b} (incorporated by reference, <i>see</i> §63.14) or Method 10 of 40 CFR appendix A. The CO concentration must be at 15 percent O ₂ , dry basis.
2. 4SRB stationary RICE.	a. Reduce formaldehyde emissions.	i. Select the sampling port location and the number of traverse points; and ii. Measure O ₂ at the inlet and outlet of the control device; and iii. Measure moisture content at the inlet and outlet of the control device; and	(1) Method 1 or 1A of 40 CFR part 60, appendix A §63.7(d)(1)(i). (1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A, or ASTM Method D6522–00 (2005). (1) Method 4 of 40 CFR part 60, appendix A, or Test Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348–03.	(a) Sampling sites must be located at the inlet and outlet of the control device. (a) Measurements to determine O ₂ concentration must be made at the same time as the measurements for formaldehyde concentration. (a) Measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde concentration.